

*Revise definition for 'FLOOD HAZARD AREA' to read as follows:

The greater of the following two areas:

1. The area within a flood plain subject to a 1-percent or greater chance of flooding in any year. For Risk Categories II, III, and IV structures, the Flood Hazard Area shall be the 500-year floodplain designated as the Special Flood Hazard Area and the Shaded X-Zone. For Risk Category I structures, the Flood Hazard Area shall be the 100-year floodplain designated as the Special Flood Hazard Area.
2. The area designated as a flood hazard area on a community's flood hazard map, or otherwise legally designated.

*Revise Section 1612.2 'Design and construction' to read as follows:

The design and construction of buildings and structures located in flood hazard areas, including coastal high hazard areas and coastal A zones, shall be in accordance with Chapter 5 of ASCE 7 including Supplement 2, and ASCE 24. Elevators, escalators, conveying systems and their components shall conform to ASCE 24 and ASME A17.1/CSA B44 as applicable.

Exception: Temporary structures complying with Section 3103.6.1.3.

*Revise Chapter 35 Referenced Standards ASCE/SEI 7-22 to read as follows:

ASCE/SEI 7—22 Minimum Design Loads and Associated Criteria for Buildings and Other Structures with Supplements 1 and 2