

IBC-2024-14

*Revise Section [F] 903.2.8 'Group R' to add new exception to read as follows:

[F] 903.2.8 Group R.

Refer to the applicable codes and standards adopted by the Georgia Safety Fire Commissioner."

IBC-2024-15

*Revise Section [F] 903.2.8.1 'Group R-3 to read as follows:

[F] 903.2.8.1 Group R-3. An automatic sprinkler system installed in accordance with Section 903-3.3.1.3 903.3.1.2 shall be permitted in Group R-3 occupancies.

Refer to the applicable codes and standards adopted by the Georgia Safety Fire Commissioner."

IBC-2024-16

*Revise Section [F] 903.2.8.2 'Group R-4, Condition 1' to read as follows:

[F] 903.2.8.2 Group R-4, Condition 1. An automatic sprinkler system installed in accordance with Section 903.3.1.3 903.3.1.2 shall be permitted in Group R-4, Condition 1 occupancies.

Refer to the applicable codes and standards adopted by the Georgia Safety Fire Commissioner."

IBC-2024-17

*Revise Section [F] 903.2.8.4 'Care facilities' to read as follows:

[F] 903.2.8.4 Care facilities. An automatic sprinkler system installed in accordance with Section 903.3.1.3 903.3.1.2 shall be permitted in care facilities with five or fewer individuals in a single-family dwelling.

Refer to the applicable codes and standards adopted by the Georgia Safety Fire Commissioner."

IBC-2024-18

*Revise Section [F] 903.3.1.3 'NFPA 13D sprinkler systems' to read as follows:

[F] 903.3.1.3 NFPA 13D sprinkler systems. Automatic sprinkler systems installed in one and two-family dwellings; Group R-3; Group R 4, Condition 1; and townhouses separated by 2 hour firewalls shall be permitted to be installed throughout in accordance with NFPA 13D.

Refer to the applicable codes and standards adopted by the Georgia Safety Fire Commissioner."